

# Emission Test Certificate

Monday, August 18<sup>th</sup>, 2014

Supplier: USG Boral Australia (251 Salmon Street, Port Melbourne, VIC 3207)

Sample Description: Sheetrock Brand Wall Board

Date Tested: July 2014 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

<b>ASTM D5116</b>	<b>Sheetrock Brand Wall Board</b>
Total Volatile Organic Compound Emission Rate	<0.006mg/m <sup>2</sup> /hr
Formaldehyde Emission Rate	<0.011mg/m <sup>2</sup> /hr
<p><i>The above results may be considered representative of the product specifications that are made from the same raw material by USG Boral Australia which includes Sheetrock Brand Ceiling Board.</i></p>	



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Nick Joy  
BSc(Hons)  
Consultant

**CV140736**