

VOC Content Test Certificate

Friday September 14th, 2007

Manufacturer: Boral Plasterboard (676 Lorimer Street, Port Melbourne Victoria 3207)

Sample Description: BaseCote – plaster based compound for jointing of plasterboard.

Production Date: September 2007

Date Tested: September 2007

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

<p style="text-align: center;">Specification</p> <p style="text-align: center;">Green Building Council of Australia</p> <p style="text-align: center;">Green Star Office Design V2 IEQ-13</p> <p style="text-align: center;">Green Star Office Design V3 IEQ-13</p> <p style="text-align: center;">Green Star Office Interiors V1.1 IEQ-11</p>	<p style="text-align: center;">BaseCote</p>
<p>Dry Wall and Panel Adhesive 50 grams per Litre maximum</p>	<p style="text-align: center;"><10 grams per Litre</p>

The above result is representative of all BaseCote product range manufactured and supplied by Boral Plasterboard.



Dr. Vyt Garnys
 PhD, BSc(Hons) AIMM, ARACI, ISIAQ
 ACA, AIRAH, FMA
 Managing Director and Principal Consultant

F0709-09