

# VOC Content Test Certificate

Friday September 14<sup>th</sup>, 2007

Manufacturer: Boral Plasterboard (676 Lorimer Street, Port Melbourne Victoria 3207)

Sample Description: FinalCote / TopCote 550 – finishing compound for jointing of plasterboard

Production Date: September 2007

Date Tested: September 2007

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

Specification	FinalCote / TopCote 550
<b>Green Building Council of Australia</b>	
<b>Green Star Office Design V2 IEQ-13</b>	
<b>Green Star Office Design V3 IEQ-13</b>	
<b>Green Star Office Interiors V1.1 IEQ-11</b>	
Dry Wall and Panel Adhesive 50 grams per Litre maximum	<b>14 grams per Litre</b>

The above result is representative of all FinalCote product range manufactured and supplied by Boral Plasterboard.



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant

F0709-09