

VOC Content Test Certificate

Thursday, 11th April 2013

Manufacturer: Boral Plasterboard (676 Lorimer Street, Port Melbourne Victoria 3207)

Sample Description: Pottery Plaster

Date Tested: July 2008

Test Method: SCAQMD Method 303-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

<p>Specification</p> <p>Green Building Council of Australia</p> <p>Green Star Office Design V2 IEQ-13</p> <p>Green Star Office Design V3 IEQ-13</p> <p>Green Star Office Interiors V1.1 IEQ-11</p>	<p>Pottery Plaster</p>
<p>Dry Wall and Panel Adhesive 50 grams per Litre maximum</p>	<p><10 grams per Litre</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Travis Hale
BSc
Consultant

CV130410