



Professional Scientific Solutions

VOC Content Test Certificate

Thursday, 6th January, 2011

Manufacturer: Boral Plasterboard (251 Salmon St, Port Melbourne, VIC, 3207)

Sample Description: Redibase Joint Compound

Tested: December 2010

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

Specification	
Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors V1.1 IEQ-11	Redibase Jointing Compound
Architectural Sealant 250 grams per Litre as VOC content material	<1 grams per Litre as VOC content material
Specification	
Green Building Council of Australia Green Star Office Design V3 IEQ-13	Redibase Jointing Compound
Architectural Sealant 250 grams per Litre as VOC content material	<1 grams per Litre as VOC content material

Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

F1011-36